

Date: 13/09/2009
Ref: P066/23774/sd
F17/R01/27-01-2004

To Whom It May Concern,

MANUFACTURER CERTIFICATE

We as DAMEKS, confirm and undersign that Protector by DLP Systems Early Streamer Emission Lightning Conductors are gone through the full range tests in METU laboratories and the following efficiency levels are maintained. The tests were performed according to the French Standard NF C 17 102, electrogeometric calculations.

- Protection level 1 : 98% (Calculation)
- Protection level 2 : 92% (Calculation)
- Protection level 3 : 82% (Calculation)

Dameks Co.
Sinan DAMGACIOĞLU



Date: 13/09/2009
Ref: P066/23774/sd
F17/R01/27-01-2004

Onome kome može poslužiti,

SERTIFIKAT PROIZVOĐAČA

Mi kao DAMEKS, potvrđujemo i potpisujemo da je Protector od DLP sistema gromobrana sa uređajem za rano startovanje prošao kroz pun opseg testova u METU (Bliskoistočni Tehnički Univerzitet) laboratorijama i održani su sledeći nivoi efikasnosti. Testovi su izvedeni prema Francuskom standardu NFC 17102, elektrogeometrijski proračun.

- Nivo zaštite I : 98% (izračunato)
- Nivo zaštite II : 92% (izračunato)
- Nivo zaštite III : 82% (izračunato)

Dameks Co.
Sinan DAMGACIOGLU